

PALOS WALL 3.0

4163A4A4

Project
Туре
Notes
Quantity
Date


GENERAL
Wall
Surface
Anthracite Grey
RAL 7016 ^a
IP65
Exterior
670 lm
LED
3000 K
3-step binning
OPTICAL
Wide Flood
ELECTRICAL
phase-cut dim 220 - 240 V
phase-cut dim
phase-cut dim 220 - 240 V Total connected power 10.0 W Class 1
phase-cut dim 220 - 240 V Total connected power 10.0 W Class 1
phase-cut dim 220 - 240 V Total connected power 10.0 W
phase-cut dim 220 - 240 V Total connected power 10.0 W Class 1 Safety distance 0.3 m
phase-cut dim 220 - 240 V Total connected power 10.0 W Class 1 Safety distance 0.3 m
phase-cut dim 220 - 240 V Total connected power 10.0 W Class 1 Safety distance 0.3 m
phase-cut dim 220 - 240 V Total connected power 10.0 W Class 1 Safety distance 0.3 m PHYSICAL Length 130 mm Width 100 mm
phase-cut dim 220 - 240 V Total connected power 10.0 W Class 1 Safety distance 0.3 m PHYSICAL Length 130 mm Width 100 mm

^a Color may deviate slightly due to production

conditions.












Wall surface luminaire made from aluminium; surface Anthracite Grey; powder coated; matt texture; RAL $7016; direct \ light \ distribution; PCB \ 3-step \ binning; phase-cut \ dim; light \ colour \ 3000 \ K; binning \ initial$ $MacAdam \cite{MacAdam} \cite{CRI \cite{MacAdam}} \cite{Robin} SDCM; CRI \cite{MacAdam} \cite{Robin} 80; 220 - 240 \ V; degree of protection IP65; PC1; driver included; light source$ not replaceable; control gear replaceable by end-user;



February 8, 2023



PALOS WALL 3.0

4163A4A4

Maintenance Factors

Operating T	ime [h]	10 000	20 000	30 000	40 000	50 000	
LLMF LSF		0.97	0.93	0.89	1	0.82	
MF L	LMF × RSMF × l	LLMF × LSF		$RSMF^a$	Room Surface M	aintenance Fact	tor
MF N	Maintenance Factor			LLMF	Lamp Lumens Maintenance Factor		
IME ^a I	uminaire Main	tononao Foata		ICE	Lomp Currival E	olston	

 $^{^{}a}$ According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.